



Fluid thinking...



Presenter: Ted Bennett, P.E.
May 22, 2019

Connecting Waterville to Bowling Green Water Distribution Maxi-Directional Drilling The River & The Switch



Jones & Henry
ENGINEERS, LTD.

Project Back Story


2014

Waterville's Contract for Toledo Water through Lucas County Sanitary Engineer set to expire in December 2016

Feasibility of A Contract with the City of Bowling Green Water System.

New Water Main would require

- 5000-feet of Water Main
- Maumee River is 1000' wide
- Metering
- Pressure Reducing Valve



Agreement Reached



2015

Agreement between Waterville and Bowling Green



City of BG WTP

Crossing the Maumee River

City of Waterville

© 2016 Google



Tour Guide



1995

41°29'07.25" N 83°43'53.32" W elev 608 ft eye alt 1294 ft



What is Maxi-HDD

- Trenchless Method
- Maxi-Horizontal Directional Drilling
 - Length Greater than 1,000'
 - Diameters Greater than 24"
- High Accuracy Needed



Designing a Maxi-HDD

Considerations for Success

Right People (Consultant & Contractor)

- Experienced
- Qualified

Right Plan (Plans & Specs)

- Functionality
- Constructability






Designation: F1962 – 11

Standard Guide for
Use of Maxi-Horizontal Directional Drilling
Polyethylene Pipe or Conduit Under
River Crossings¹


RIVER CROSSINGS,
POLYETHYLENE PIPE OR CONDUIT
USE OF MAXI-HORIZONTAL DIRECTIONAL

Design Guidance






Right People




Right Plan




Field Reconnaissance






Railroad Roadbed




Bedrock





Bridge Ruin



Roche de Boeuf



Soils Investigation


Objectives

- Understand Rock Characteristics – Hardness / Fractures
- Depth Below Pipe
- Construction Method Selection



Designing a Maxi-HDD

Developing the Plan and Profile



NOT TO SCALE

FIG. 1 Maxi-HDD for Obstacle (for example, River) Crossing

Source: ASTM F-1962 – Use of Maxi-Horizontal Directional Drilling for Placement of PE Pipe or Conduit Under Obstacles, Including River Crossings. (2011)



Right People

Right Plan

BAD


DESIGN

NO!



Right People

Right Plan



**Final
Design**



Right People

Right Plan

Technical Specs

Construction Specifications / Performance Requirements

Typical Requirements

- Tracking & Accuracy
- Make Staging Area Big
- Plan for Bore Fluid Management
- What Happens if you Frac-out?
- Accuracy Expectations
- Identify the Failure Paths



City of Waterville, Ohio Maumee River Water Transmission Main

2016

Advertisement, Instruction for Bidders,
Bid, Agreement, Bonds, General and
Supplementary Conditions, and Specifications

Leti Bredie - Mayor
Members of City Council
Timothy Pedro Charles Larkins
Barb Benson James Valtin
Michelle Kriss John Rasic
Administration
James M. Szponoski, P.E., P.S. - Municipal Administrator
Jon Gochensour - Finance Director

Jones & Henry Engineers, Ltd.
www.jhe.com
Fluid Thinking[®]



Right People

Right Plan

Contractor Selection

Construction Specifications / Performance Requirements

Contractor Qualifications

- Guidance and Tracking
- Personnel
- Past Performance
 - Size & Scope of Projects
 - Soil Conditions
 - Project Costs
- Equipment



Drill Machine
250,000lb Thrust / Pullback

City of Waterville, Ohio
Maumee River Water Transmission Main

2016

Advertisement, Instruction for Bidders,
Bid, Agreement, Bonds, General and
Supplementary Conditions, and Specifications

Levi Bredie - Mayor
Members of City Council
Timothy Pedro Charles Larkins
Barb Bruno James Valtin
Micheline Kriss John Rasic
Administration
James M. Szpionat, P.E., P.S. - Municipal Administrator
Jon Gochanour - Finance Director

 Jones & Henry Engineers, Ltd.
www.jh-eng.com Fluid Thinking[®]



Construction Phase




- Total HDD Drill and Pullback - 35 days






Directional Mud Motor



Pilot Hole-Out



9" Pilot Hole Reaming Bit

Pipe Installation – Pilot Hole

9" Pilot Hole Reamer – 9 days





30" Reamer



Ream Out




Pull Reaming
80,000 Pull Force

Pipe Installation – Reaming

24" Reamer – 16 days

30" Reamer – 10 days





Pipe Pullback – 13 hours





Fusion Machine


- Pre-test with low air pressure prior to pullback
- Water Pressure test after pullback



Pressure Testing



Pressure Testing



*Pipe Installed @ Elevation 575 – 30' Depth Below River




Right People

Right Plan



As-Built

Design Vertical and Horizontal Curves Held Pipe Deepened to 30' Cover



Construction Wrap Up

- Engineer's Estimate = \$2.5
- Project Bid Price = \$2.2 million
- Bore Price = \$1.7 million (~\$970 / ft)
- Final Project Cost = \$2.2 million
- River Crossing Commence: July 18, 2016
- River Crossing Completion: September 1, 2016
- Project Substantial Completion: February 2017
- Project Final Completion: April 2017



City of Waterville switches water sources today

Starts to draw water from Bowling Green after shutting off Toledo connection

THE SWITCH Regulatory Review

Pressure Zone Changes

Velocity Magnitude Change


Velocity Direction Change

Water Chemistry



SO WHAT YOU'RE SAYING IS

Discharge Pressure: 90 psi



Waterville Tower



BG WTP

THERE IS ENERGY GRADE DIFFERENTIAL?



Addressing The Pressure Differential

BG Pressure 90
psi

WV Pressure
60 psi

PRV





The Velocity Concern

- Changes in Magnitude and Direction could cause:
 - Biofilm Stripping
 - Sediment Fluidization
 - Protective Coating Shearing






Literature Review Water Main Velocity

- Consensus
 - Sediment Particle sizes vs velocity
 - AWWA & 10 States – 2.5 fps for scouring (new pipe)
 - Velocity must be greater than 5 – 6 fps to scour (ex pipe)
 - Not much information about directional switch




Velocity Magnitude Evaluation WaterCAD


- Existing System
- Pipes with Velocity > 2.5 fps
- Maximum velocities near Lucas Co. connection and existing tanks.
- Only two pipes predicted to have a maximum velocity exceeding 5 fps.



Velocity Magnitude Evaluation WaterCAD

- Proposed System
- Pipes with Velocity > 2.5 fps
- Maximum velocities near Bowling Green connection and existing tanks.
- Only one pipe predicted to have a maximum velocity exceeding 5 fps.





Velocity Direction Switch Evaluation Water CAD

- Pipes with 5 fps of direction change
- Locations near Bowling Green
- Locations near removed feed from the Lucas County
- Locations feeding towers experience greater than 5 fps switch feed towers
- Pipes with directional changes experience daily flow switching.





Velocity Direction Switch Evaluation (Permanent) - Water CAD

- All permanent switches below 5 fps
- Impacts minimal



Water Chemistry Concerns

- Water Chemistry Similar
- Alkalinity of BG slightly higher than Toledo
- OEPA required a reduction in Alkalinity by BG prior to switch
- Waterville resumed Lead & Copper



Final Points – “Mission Accomplished”

Construction

- Background Investigations and Analysis Critical
- Project Specific Technical Specifications and Drawings
- Constructible Pipe Geometry

Supply Switch

- Water Chemistry Evaluation
- Water Flow Study
- Seamless Switch



Questions?

Ted Bennett, P.E.
Jones & Henry Engineers, Ltd.
tbennett@jheng.com
419-473-9611
🐦 @TedBennettPE

